

ADDENDUM NO. 03

PROJECT NAME: Inventory Building on East Campus
NU PROJECT NUMBER: 10978
BID INVITATION NUMBER: 3029-19-7200

CONSULTANT: Architectural Design Associates, P.C.
ADDRESS: 7501 "O" Street, Ste. 105, Lincoln, NE 68510

DATE OF ISSUANCE: February 14, 2019
DATE OF BID OPENING: February 14, 2019 (SEE REVISED DATE)
REVISED DATE OF BID OPENING: February 19, 2019 at 2:00 pm

The bid documents dated 01.04.2019 for the above referenced project are amended by this addendum.

NOTICE: This Addendum is issued to all interested prospective bidders as an amendment to the project manual or other parts of the bidding (contract) documents for the above named project. Reference to this Addendum must be included in the Bid proposal. The information contained herein shall be fully incorporated into the contract documents as though originally included therein.

QUESTIONS AND ANSWERS:

1. **QUESTION:** *In addendum #2, there is question #4 discussing shelving & racks. Was this just a question from a sprinkler guy?*

NU RESPONSE: Yes, this only pertained to Sprinkler layout and coverage. The University will provide all their own shelving and racks and perform install.

2. **QUESTION:** *Most drawings have a 4" fire line called out. Sheet E0.1 call for a 6" fire line. Please confirm the 4" fire line is the diameter of the fire line to be bid.*

NU RESPONSE: AES spoke with a Fire Protection company and a 6" fire service will be need to be bid.

MODIFICATIONS TO THE PROJECT MANUAL

MODIFICATION / SUBSTITUTION

None on Addendum No. 3

MODIFICATIONS TO THE DRAWINGS:

DRAWING: None on Addendum No. 3

- Final Addendum – No Further Questions will be answered, good luck all and thank you for your time and efforts.

END OF ADDENDUM NO. 3